

General Environmental Incident Summary

Incident: 3445 **Date/Time Notice:** 9/3/2014 0912 **DEM Incident No:**

Responsible Party: Unknown

Date Incident: 8/30/2014 **Time Incident:** 0430 **Duration:**

County: McKenzie **Twp:** 150 **Rng:** 99 **Sec:** 24 **Qtr:**

Lat: 47.80131 **Long:** -103.28300 **Method:** Interpolation from map

Location Description: Kum and Go # 804- 124 S Main St. Watford City, ND

Submitted By: Amy Wilkerson

Affiliation: Seneca Environmental

Address: 4140 E 14th St

City: Des Moines

State: IA

Zip: 50313

Received By:

Contact Person:

Unknown

Unknown, ND

Distance Nearest Occupied Building:

Release Contained: Yes

Type of Incident: Tank Overflow

Description of Released Contaminant: Unleaded gasoline

Volume Spilled: 25.00 gallons

Ag Related: No

EPA Extremely Hazardous Substance: Unknown

Reported to NRC: Unknown

Cause of Incident:

Auto shutoff did not engage on pump 13.

Risk Evaluation:

none

of Fatalities:

of Injuries:

Affected Medium: 01 - air

Potential Environmental Impacts:

None- did not leave site or enter any storm drains

Action Taken or Planned:

Store called fire department to clean spill.

Wastes Disposal Location:

Agencies Involved: Local Fire Department

Updates

Date: 9/3/2014

Status: Reviewed; Followup Required

Author: Roberts, Kris

Updated Volume:

Notes:

Kum and Go Station - Watford City. Follow-up necessary.

Date: 9/4/2014

Status: Reviewed; Followup Required

Author: Martin, Russell

Updated Volume:

Notes:

Release due to auto shutoff not engaging on a pump. Release remained on site but is not at an E&P exempt facility. Followup is necessary.

Date: 9/5/2014

Status: Inspected

Author: Martin, Russell

Updated Volume:

Notes:

9/5/2014 at 15:35, on location. Met with employee of store. Apparently, location did not have any absorbent material to clean up spill. Cleanup was handled by fire department. Plastic bag currently over handle of gas nozzle at pump 13, but no stains related to spill are visible on the concrete.